

Distribution Station	Upstream Station	Service Area	Year Energized	Voltage	Transformer Size	No. of Feeders	HV Protection	LV Protection
Cardinal MS1	Morrisburg TS Restricted	North of Hwy 2	Jun-53	44 – 2.4 kV	3.0 MVA	2 Restricted	65E	400A Fuses
Cardinal MS2	Morrisburg TS Restricted	South of Hwy 2	Sep-96	44 – 2.4 kV	3.0 MVA	2 Restricted	65E	400A Fuses
Iroquois MS1	Morrisburg TS Restricted	Iroquois	Jun 1953 (T1)	44 – 4.8 kV	3.0 MVA	2 Restricted	100E	300A Fuses 200A Reclosure
(back-up tx)			Feb 2016 (T2)	44 – 4.8 kV	3.0 MVA		100E	400A Fuses
Morrisburg MS1	Morrisburg TS Restricted	South of Cty Rd 2	Sep-76	44 – 2.4 kV	5.0 MVA	4 Restricted	150E	400A Fuses
Morrisburg MS2	Morrisburg TS Restricted	North of Cty Rd 2	Jun-89	44 – 2.4 kV	5.0 MVA	2 Restricted	150E	400A Fuses
Prescott MS1/QL2	Brockville	West Town	1965	44 – 2.4 kV	3.0 MVA	3	SMD-50	400A Fuses
Prescott MS2/QL20	Brockville	Centre Town	1954-06-01 Reburb 2017	44 – 2.4 kV	5.0 MVA	2	80E	400A Fuses
Prescott MS3/QL40	Brockville	North West Town	Jun-63	44 – 2.4 kV	5.0 MVA	4	100E	400A Fuses
Prescott MS4/QL30	Brockville	East Town	Oct-91	44 – 2.4 kV	5.0 MVA	2	60F	400A Reclosure
Glenbecker DS (Hydro One)	Morrisburg TS Restricted	Williamsburg	-	44-8.32 kV	-	1 - F3 Restricted	-	-
Newboro DS (Hydro One)	Crosby TS	Westport	-	27.5-8.32 kV	-	1- F2	-	-